

Corridor
Walkways
Accent
General Lighting




Specifications



- Certifications** The fixture shall be ETL and CETL listed for wet location and concrete pour. Also listed for wire through. The fixture shall meet ADA requirements.
- Lamp/Ballast Housing** Cast aluminum with a minimum wall thickness of 3/16" and two 3/4" NPT conduit entrances for through-wiring capability.
- Face Plate** Cast aluminum standard with cast bronze optional. Secured to lamp/ballast housing with eight 10-24 stainless steel Allen cap screws. Gasketed to prevent entrance of dust, insects and moisture.
- Lens** Tempered clear glass sealed to face plate with high temperature silicone.
- Lamp Holder** Porcelain 4KV pulse rated medium base, for HID and Incandescent lamp source.
- Reflector** Highly polished specular aluminum multifaceted for optimum efficiency.
- Finish** BK-BZ-WH-GR-GY-NA baked enamel standard, other colors available.

PROJECT
FIXTURE TYPE
CATALOG#

 Some luminaires use fluorescent or high intensity discharge (HID) lamps that contain small amounts of mercury. Such lamps are labeled "Contains Mercury" and/or with the symbol "Hg." Lamps that contain mercury must be disposed of in accordance with local requirements. Information regarding lamp recycling and disposal can be found at www.lamprecycle.org

Product Order Guide

Series	Max Watts	Lamp Type	Voltage ¹	Finish ¹	Options
SP-28	100 MH	E17	120	BK Black	QS Quartz Standby
	100 HPS	E17	208	BZ Bronze	EMG Emergency Battery Backup
	42 CFT	CFT ²	240	WH White	
	13 CF	CF ²	277	GR Green	
	26 CFQ	CFQ ²		NA Natural Aluminum	
				GY Gray	
				CC Custom Color	

1 Consult factory for other colors and voltages

2 CF = single biax, CFQ = double biax, CFT = triple biax

Example: SP-28-100MH-E17-120-BK

Luminaire Dimensions

Luminaire	A		B		Weight	
	Inch	mm	Inch	mm	lbs.	kg
SP-28	14.0	356	6.5	165	30	13.6

